



Microbac Laboratories, Inc., New York Division
CERTIFICATE OF ANALYSIS

J0J0941

Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCES

Project Name: Glen Park

Fred Hauck
 20104 NYS Route 3
 Watertown, NY 13601

Project / PO Number: N/A
 Received: 10/09/2020
 Reported: 10/31/2020

Analytical Testing Parameters

Client Sample ID: 9	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0941-01		Collection Date: 10/05/2020 6:38

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0059	0.015 AL	0.0010	mg/L		10/22/20 1335	10/23/20 1259	DLO

Client Sample ID: 28	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0941-02		Collection Date: 10/05/2020 6:43

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0165	0.015 AL	0.0010	mg/L		10/22/20 1335	10/23/20 1303	DLO

Client Sample ID: 30	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0941-03		Collection Date: 10/05/2020 6:46

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0107	0.015 AL	0.0010	mg/L		10/22/20 1335	10/23/20 1305	DLO

Client Sample ID: 36	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0941-04		Collection Date: 10/05/2020 6:18

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0484	0.015 AL	0.0010	mg/L		10/22/20 1335	10/23/20 1310	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J0941

Client Sample ID: 32	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0941-05		Collection Date: 10/05/2020 6:45

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0106	0.015 AL	0.0010	mg/L		10/22/20 1335	10/23/20 1312	DLO

Client Sample ID: 37	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0941-06		Collection Date: 10/05/2020 6:49

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0020	0.015 AL	0.0010	mg/L		10/22/20 1335	10/23/20 1314	DLO

Client Sample ID: 39	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0941-07		Collection Date: 10/05/2020 6:50

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0045	0.015 AL	0.0010	mg/L		10/22/20 1335	10/23/20 1316	DLO

Client Sample ID: 11	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0941-08		Collection Date: 10/05/2020 6:35

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0068	0.015 AL	0.0010	mg/L		10/22/20 1335	10/23/20 1318	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J0941

Client Sample ID: 81	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0941-09		Collection Date: 10/05/2020 6:31

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0177	0.015 AL	0.0010	mg/L		10/22/20 1335	10/23/20 1319	DLO

Client Sample ID: 80	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0941-10		Collection Date: 10/05/2020 6:31

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0099	0.015 AL	0.0010	mg/L		10/22/20 1335	10/23/20 1321	DLO

Client Sample ID: 20	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0941-11		Collection Date: 10/05/2020 6:37

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0064	0.015 AL	0.0010	mg/L		10/23/20 1016	10/23/20 1123	LLW

Client Sample ID: 35	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0941-12		Collection Date: 10/05/2020 6:48

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.146	0.015 AL	0.0050	mg/L		10/23/20 1406	10/26/20 1530	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J0941

Client Sample ID: 83	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0941-13		Collection Date: 10/05/2020 7:01

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0030	0.015 AL	0.0010	mg/L		10/23/20 1016	10/23/20 1129	LLW

Client Sample ID: 82	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0941-14		Collection Date: 10/05/2020 7:00

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0352	0.015 AL	0.0010	mg/L		10/23/20 1016	10/23/20 1131	LLW

Client Sample ID: 60	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0941-15		Collection Date: 10/05/2020 7:01

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0074	0.015 AL	0.0010	mg/L		10/23/20 1016	10/23/20 1132	LLW

Client Sample ID: 51	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0941-16		Collection Date: 10/05/2020 7:02

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0037	0.015 AL	0.0010	mg/L		10/23/20 1016	10/23/20 1134	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J0941

Client Sample ID: 48	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0941-17		Collection Date: 10/05/2020 7:01

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0029	0.015 AL	0.0010	mg/L		10/23/20 1016	10/23/20 1140	LLW

Client Sample ID: 63	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0941-18		Collection Date: 10/05/2020 7:10

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0130	0.015 AL	0.0010	mg/L		10/23/20 1016	10/23/20 1142	LLW

Client Sample ID: 22	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0941-19		Collection Date: 10/05/2020 6:13

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0031	0.015 AL	0.0010	mg/L		10/23/20 1016	10/23/20 1143	LLW

Client Sample ID: 17	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0941-20		Collection Date: 10/05/2020 6:43

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0061	0.015 AL	0.0010	mg/L		10/23/20 1016	10/23/20 1145	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J0941

Client Sample ID: 59	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0941-21		Collection Date: 10/05/2020 7:08

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0073	0.015 AL	0.0010	mg/L		10/23/20 1016	10/23/20 1147	LLW

Client Sample ID: 58	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0941-22		Collection Date: 10/05/2020 7:08

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0088	0.015 AL	0.0010	mg/L		10/23/20 1016	10/23/20 1149	LLW

Client Sample ID: 45	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0941-23		Collection Date: 10/05/2020 7:00

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0046	0.015 AL	0.0010	mg/L		10/23/20 1016	10/23/20 1153	LLW

Client Sample ID: 52	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0941-24		Collection Date: 10/05/2020 7:02

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0040	0.015 AL	0.0010	mg/L		10/23/20 1016	10/23/20 1154	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J0941

Client Sample ID: 15	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0941-25		Collection Date: 10/05/2020 6:25

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0034	0.015 AL	0.0010	mg/L		10/23/20 1137	10/23/20 1330	DLO

Client Sample ID: 8	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0941-26		Collection Date: 10/05/2020 6:32

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0062	0.015 AL	0.0010	mg/L		10/23/20 1137	10/23/20 1336	DLO

Client Sample ID: 24	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0941-27		Collection Date: 10/05/2020 6:41

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0077	0.015 AL	0.0010	mg/L		10/23/20 1137	10/23/20 1338	DLO

Client Sample ID: 26	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0941-28		Collection Date: 10/05/2020 6:45

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0069	0.015 AL	0.0010	mg/L		10/23/20 1137	10/23/20 1340	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J0941

Client Sample ID: 5	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0941-29		Collection Date: 10/05/2020 6:32

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0095	0.015 AL	0.0010	mg/L		10/23/20 1137	10/23/20 1341	DLO

Client Sample ID: 13	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0941-30		Collection Date: 10/05/2020 6:35

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0086	0.015 AL	0.0010	mg/L		10/23/20 1137	10/23/20 1343	DLO

Client Sample ID: 2	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0941-31		Collection Date: 10/05/2020 6:30

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0044	0.015 AL	0.0010	mg/L		10/23/20 1137	10/26/20 1451	DLO

Client Sample ID: 1	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0941-32		Collection Date: 10/05/2020 6:30

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0145	0.015 AL	0.0010	mg/L		10/23/20 1137	10/26/20 1453	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J0941

Client Sample ID: 71	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0941-33		Collection Date: 10/05/2020 7:16

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0076	0.015 AL	0.0010	mg/L		10/23/20 1137	10/26/20 1455	DLO

Client Sample ID: 65	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0941-34		Collection Date: 10/05/2020 7:12

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0079	0.015 AL	0.0010	mg/L		10/23/20 1137	10/26/20 1456	DLO

Client Sample ID: 67	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0941-35		Collection Date: 10/05/2020 7:14

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0038	0.015 AL	0.0010	mg/L		10/23/20 1137	10/26/20 1502	DLO

Client Sample ID: 76	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0941-36		Collection Date: 10/05/2020 7:31

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0021	0.015 AL	0.0010	mg/L		10/23/20 1137	10/26/20 1506	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J0941

Client Sample ID: 84	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0941-37		Collection Date: 10/05/2020 7:47

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0124	0.015 AL	0.0010	mg/L		10/23/20 1137	10/26/20 1508	DLO

Client Sample ID: 68	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0941-38		Collection Date: 10/05/2020 7:15

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0047	0.015 AL	0.0010	mg/L		10/23/20 1137	10/26/20 1509	DLO

Client Sample ID: 69	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0941-39		Collection Date: 10/05/2020 7:15

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0039	0.015 AL	0.0010	mg/L		10/23/20 1137	10/26/20 1511	DLO

Client Sample ID: 62	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0941-40		Collection Date: 10/05/2020 7:10

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0039	0.015 AL	0.0010	mg/L		10/23/20 1137	10/26/20 1513	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J0941

Client Sample ID: 64	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0941-41		Collection Date: 10/05/2020 7:12

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0039	0.015 AL	0.0010	mg/L		10/23/20 1137	10/26/20 1515	DLO

Client Sample ID: 42	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0941-42		Collection Date: 10/05/2020 6:58

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0024	0.015 AL	0.0010	mg/L		10/23/20 1137	10/26/20 1517	DLO

Client Sample ID: 47	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0941-43		Collection Date: 10/05/2020 7:01

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0225	0.015 AL	0.0010	mg/L		10/23/20 1137	10/26/20 1518	DLO

Client Sample ID: 54	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0941-44		Collection Date: 10/05/2020 7:05

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0071	0.015 AL	0.0010	mg/L		10/23/20 1137	10/26/20 1528	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J0941

Client Sample ID: 61	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0941-45		Collection Date: 10/05/2020 7:09

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0045	0.015 AL	0.0010	mg/L		10/23/20 1352	10/26/20 1325	DLO

Client Sample ID: 66	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0941-46		Collection Date: 10/05/2020 7:13

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0056	0.015 AL	0.0010	mg/L		10/23/20 1352	10/26/20 1331	DLO

Client Sample ID: 41	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0941-47		Collection Date: 10/05/2020 6:58

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0871	0.015 AL	0.0010	mg/L		10/23/20 1352	10/26/20 1332	DLO

Client Sample ID: 46	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0941-48		Collection Date: 10/05/2020 7:00

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0174	0.015 AL	0.0010	mg/L		10/23/20 1352	10/26/20 1334	DLO



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J0941

Client Sample ID: 57	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0941-49		Collection Date: 10/05/2020 7:07

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0060	0.015 AL	0.0010	mg/L		10/23/20 1352	10/26/20 1336	DLO

Client Sample ID: 56	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0941-50		Collection Date: 10/05/2020 7:07

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0070	0.015 AL	0.0010	mg/L		10/23/20 1352	10/26/20 1338	DLO

Client Sample ID: 55	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0941-51		Collection Date: 10/05/2020 7:06

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0049	0.015 AL	0.0010	mg/L		10/23/20 1352	10/26/20 1343	DLO

Client Sample ID: 53	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J0941-52		Collection Date: 10/05/2020 7:05

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0045	0.015 AL	0.0010	mg/L		10/23/20 1352	10/26/20 1345	DLO

Results in bold have exceeded a limit defined for this project. Limits are provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.

Definitions

- AL: US EPA Action Level
- mg/L: Milligrams per Liter
- RL: Reporting Limit



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J0941

Project Requested Certification(s)

Microbac Laboratories, Inc. - Dayville
11549

New York State Department of Health

Microbac Laboratories, Inc., New York Division
NY Lab ID No.: 10795

New York State Department of Health

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

*The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. **The services were provided under and subject to Microbac's standard terms and conditions which can be located and reviewed at <https://www.microbac.com/standard-terms-conditions>.***

Reviewed and Approved By:

A handwritten signature in black ink that reads "Shannon Weeks". The signature is written in a cursive style and is contained within a light blue rectangular box.

Shannon Weeks
Customer Relationship Coordinator
Reported: 10/31/2020 06:15

Microbac Laboratories, Inc.

3821 Buck Dr. | Cortland, NY 13045 | 607-753-3403 p | www.microbac.com

Caley Park

Client Information			Billing/Invoice:			Analysis Requested			Receiving Info (Lab Use Only)			
Name:	Jeff/Lew Bocces								Ice:	YES	NO	
Address:	20104 NYS Route 3								Cooler:	YES	NO	
Contact:	Health/Safety Dept.								Sample Temp:	YES	NO	
Phone:	315-779-7000								Cooler seal:	YES	NO	
Project:	Lead Testing	PO#:							Pickup:	YES	NO	
Quote ID:		Date Req.:							Dropoff:	C	W	
Rush TAT Bus. Days:	<2 2-5 5-7 7-10								Accepted?	YES	NO	
Carbon Copy:	Yes								Container Material			
Email Results:	Yes	rfilley@boces.com, fhauck@boces.com, ishaw@boces.com							Container Size (in MI)			
Fax Results:	Yes								Preservative			

Sample Information			Number of Containers for Analysis Requested			Comments/Field Data		
Description/Location	Date	Time	Matrix	Type				
28	10/5	6:38	DW	DW	1			
29		6:43						
30		6:46						
31		6:48						
32		6:45						
33		6:49						
34		6:50						
35		6:55						
36		6:51						
37		6:57						
38		6:48						
39								
40								
41								
42								
43								
44								
45								
46								
47								
48								
49								
50								

Sampled:	<i>[Signature]</i>	Print Name and Company	
Received:	<i>[Signature]</i>	Date/Time	10/5/2020
Received:	<i>[Signature]</i>	Date/Time	10/9/2020 1600
		Comments	




Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.

Microbac Laboratories, Inc. CHAIN OF CUSTODY

3821 Buck Drive
 Cortland NY 13045
 Phone: (607)753-3403 Fax: (607)753-3415
 NY #10795, EPA #NY00935

Samples must be returned on ice
 MNY Workorder #

Client Information		Billing/Invoices		Analysis Requested		Receiving Info (Lab Use Only)	
Name:	Jeff/Lew Boces					Ice:	YES NO
Address:	20104 NYS Route 3					Cooler:	YES NO
Contact:	Health/Safety Dept.					Sample Temp:	YES NO
Phone:	315-779-7000					Cooler seal:	YES NO
Project:	Lead Testing					Pickup:	YES NO
Quote ID:	PO#					Dropoff:	C W
Rush TAT Bus. Days: <2 2-5 5-7 7-10	Date Req:					Accepted?	YES NO
Carbon Copy: Yes						Container Material	
Email Results: Yes	rfilley@boces.com, fhauck@boces.com, lshaw@boces.com					Container Size (in MI)	
Fax Results: Yes						Preservative	
Sample Information				Number of Containers for Analysis Requested			
Description/Location	Date	Time	Matrix	Type			Comments/Field Data
83	10/5	701	DW	DW	1		
82		700					
80		701					
81		702					
48		701					
63		710					
72		623					
77		643					
59		708					
58		708					
45		700					
52		702					
15		625					
8		1932					
24		641					
26		645					
5		632					
13		635					
2		630					
1		630					
Sampled: 				Date/Time	10/5/2020		
Received:							
Received:							

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.

Green Park

Microbac Laboratories, Inc.
CHAIN OF CUSTODY

Samples must be returned on ice
 MNY Workorder #

Client Information		Billing/Invoice:	
Name: Jeff/Lew Boces			
Address: 20104 NYS Route 3			
Contact: Health/Safety Dept.			
Phone: 315-779-7000			
Project: Lead Testing		PO#:	
Quote ID: 2-5 3-7 7-10		Date Req:	
Rush TAT Bus. Days: 2-5 3-7 7-10			
Carbon Copy: Yes			
Email Results: Yes		rfilley@boces.com, frauck@boces.com, lshaw@boces.com	
Fax Results: Yes			
Sample Information		Matrix	
Description/Location		Type	
1	71	Date	Time
2	65	10/5	716
3	67		712
4	76		714
5	84		731
6	68		747
7	69		715
8	62		715
9	64		710
10	42		712
11	47		658
12	54		701
13	61		705
14	66		709
15	41		713
16	46		658
17	57		700
18	56		707
19	55		706
20	53		705
Print Name and Company			
Sampled: <i>[Signature]</i>		Date/Time: 10/5/2020	
Received:		Comments	
Received:			

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.