



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J7D0690

Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCES

Project Name: GB-3

Fred Hauck
20104 NYS Route 3
Watertown, NY 13601

Project / PO Number: N/A
Received: 04/06/2017 13:05
Reported: 04/18/2017 12:48

Analytical Testing Parameters

Client Sample ID: 2
Lab Sample ID: J7D0690-01
Sample Type: Grab

Collected By: RF-Client
Collection Date: 04/05/17
Collection Time: 06:50

Table with 9 columns: Lead and/or Copper, Total - ICP/MS, Result, AL, PQL, Units, Note, Prepared, Analyzed, Lab. Row 1: Lead, 0.0274, 0.0150, 0.000500, mg/L, G, 04/13/17 1200, 04/13/17 1541, NY.

Analytical Testing Parameters

Client Sample ID: 10
Lab Sample ID: J7D0690-02
Sample Type: Grab

Collected By: RF-Client
Collection Date: 04/05/17
Collection Time: 06:41

Table with 9 columns: Lead and/or Copper, Total - ICP/MS, Result, AL, PQL, Units, Note, Prepared, Analyzed, Lab. Row 1: Lead, 0.00191, 0.0150, 0.000500, mg/L, 04/13/17 1200, 04/13/17 1541, NY.

Analytical Testing Parameters

Client Sample ID: 48
Lab Sample ID: J7D0690-03
Sample Type: Grab

Collected By: RF-Client
Collection Date: 04/05/17
Collection Time: 07:05

Table with 9 columns: Lead and/or Copper, Total - ICP/MS, Result, AL, PQL, Units, Note, Prepared, Analyzed, Lab. Row 1: Lead, 0.00968, 0.0150, 0.000500, mg/L, 04/13/17 1200, 04/13/17 1541, NY.

Analytical Testing Parameters

Client Sample ID: 40
Lab Sample ID: J7D0690-04
Sample Type: Grab

Collected By: RF-Client
Collection Date: 04/05/17
Collection Time: 07:04

Table with 9 columns: Lead and/or Copper, Total - ICP/MS, Result, AL, PQL, Units, Note, Prepared, Analyzed, Lab. Row 1: Lead, 0.0142, 0.0150, 0.000500, mg/L, 04/13/17 1200, 04/13/17 1541, NY.



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J7D0690

Analytical Testing Parameters

Client Sample ID: 39
Lab Sample ID: J7D0690-05
Sample Type: Grab

Collected By: RF-Client
Collection Date: 04/05/17
Collection Time: 07:04

Table with 9 columns: Lead and/or Copper, Total - ICP/MS, Result, AL, PQL, Units, Note, Prepared, Analyzed, Lab. Row 1: Lead, 0.0110, 0.0150, 0.000500, mg/L, 04/13/17 1200, 04/13/17 1541, NY

Analytical Testing Parameters

Client Sample ID: 36
Lab Sample ID: J7D0690-06
Sample Type: Grab

Collected By: RF-Client
Collection Date: 04/05/17
Collection Time: 07:02

Table with 9 columns: Lead and/or Copper, Total - ICP/MS, Result, AL, PQL, Units, Note, Prepared, Analyzed, Lab. Row 1: Lead, 0.00596, 0.0150, 0.000500, mg/L, 04/12/17 0854, 04/13/17 1541, NY

Analytical Testing Parameters

Client Sample ID: 7
Lab Sample ID: J7D0690-07
Sample Type: Grab

Collected By: RF-Client
Collection Date: 04/05/17
Collection Time: 06:43

Table with 9 columns: Lead and/or Copper, Total - ICP/MS, Result, AL, PQL, Units, Note, Prepared, Analyzed, Lab. Row 1: Lead, 0.0182, 0.0150, 0.000500, mg/L, G, 04/13/17 1200, 04/13/17 1541, NY

Analytical Testing Parameters

Client Sample ID: 1
Lab Sample ID: J7D0690-08
Sample Type: Grab

Collected By: RF-Client
Collection Date: 04/05/17
Collection Time: 06:38

Table with 9 columns: Lead and/or Copper, Total - ICP/MS, Result, AL, PQL, Units, Note, Prepared, Analyzed, Lab. Row 1: Lead, 0.0262, 0.0150, 0.000500, mg/L, G, 04/13/17 1200, 04/13/17 1541, NY



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J7D0690

Analytical Testing Parameters

Client Sample ID: 34
Lab Sample ID: J7D0690-09
Sample Type: Grab

Collected By: RF-Client
Collection Date: 04/05/17
Collection Time: 07:01

Table with 9 columns: Lead and/or Copper, Total - ICP/MS, Result, AL, PQL, Units, Note, Prepared, Analyzed, Lab. Row 1: Lead, 0.00127, 0.0150, 0.000500, mg/L, 04/12/17 0854, 04/13/17 1541, NY

Analytical Testing Parameters

Client Sample ID: 24
Lab Sample ID: J7D0690-10
Sample Type: Grab

Collected By: RF-Client
Collection Date: 04/05/17
Collection Time: 07:05

Table with 9 columns: Lead and/or Copper, Total - ICP/MS, Result, AL, PQL, Units, Note, Prepared, Analyzed, Lab. Row 1: Lead, 0.00618, 0.0150, 0.000500, mg/L, 04/12/17 0854, 04/13/17 1541, NY

Analytical Testing Parameters

Client Sample ID: 25
Lab Sample ID: J7D0690-11
Sample Type: Grab

Collected By: RF-Client
Collection Date: 04/05/17
Collection Time: 07:09

Table with 9 columns: Lead and/or Copper, Total - ICP/MS, Result, AL, PQL, Units, Note, Prepared, Analyzed, Lab. Row 1: Lead, 0.00349, 0.0150, 0.000500, mg/L, 04/12/17 0854, 04/13/17 1541, NY

Analytical Testing Parameters

Client Sample ID: 29
Lab Sample ID: J7D0690-12
Sample Type: Grab

Collected By: RF-Client
Collection Date: 04/05/17
Collection Time: 07:10

Table with 9 columns: Lead and/or Copper, Total - ICP/MS, Result, AL, PQL, Units, Note, Prepared, Analyzed, Lab. Row 1: Lead, 0.00354, 0.0150, 0.000500, mg/L, 04/12/17 0854, 04/13/17 1541, NY



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J7D0690

Analytical Testing Parameters

Client Sample ID: 47
Lab Sample ID: J7D0690-13
Sample Type: Grab

Collected By: RF-Client
Collection Date: 04/05/17
Collection Time: 07:05

Table with 9 columns: Lead and/or Copper, Total - ICP/MS, Result, AL, PQL, Units, Note, Prepared, Analyzed, Lab. Row 1: Lead, 0.0137, 0.0150, 0.000500, mg/L, 04/12/17 0854, 04/13/17 1541, NY.

Analytical Testing Parameters

Client Sample ID: 19
Lab Sample ID: J7D0690-14
Sample Type: Grab

Collected By: RF-Client
Collection Date: 04/05/17
Collection Time: 07:22

Table with 9 columns: Lead and/or Copper, Total - ICP/MS, Result, AL, PQL, Units, Note, Prepared, Analyzed, Lab. Row 1: Lead, 0.00352, 0.0150, 0.000500, mg/L, 04/12/17 0854, 04/13/17 1541, NY.

Analytical Testing Parameters

Client Sample ID: 16
Lab Sample ID: J7D0690-15
Sample Type: Grab

Collected By: RF-Client
Collection Date: 04/05/17
Collection Time: 07:21

Table with 9 columns: Lead and/or Copper, Total - ICP/MS, Result, AL, PQL, Units, Note, Prepared, Analyzed, Lab. Row 1: Lead, 0.00210, 0.0150, 0.000500, mg/L, 04/12/17 0854, 04/13/17 1541, NY.

Analytical Testing Parameters

Client Sample ID: 11
Lab Sample ID: J7D0690-16
Sample Type: Grab

Collected By: RF-Client
Collection Date: 04/05/17
Collection Time: 07:22

Table with 9 columns: Lead and/or Copper, Total - ICP/MS, Result, AL, PQL, Units, Note, Prepared, Analyzed, Lab. Row 1: Lead, 0.00150, 0.0150, 0.000500, mg/L, 04/12/17 0854, 04/13/17 1541, NY.



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J7D0690

Analytical Testing Parameters

Client Sample ID: 3
Lab Sample ID: J7D0690-17
Sample Type: Grab

Collected By: RF-Client
Collection Date: 04/05/17
Collection Time: 06:39

Table with 9 columns: Lead and/or Copper, Total - ICP/MS, Result, AL, PQL, Units, Note, Prepared, Analyzed, Lab. Row 1: Lead, 0.0433, 0.0150, 0.000500, mg/L, G, 04/13/17 1200, 04/13/17 1541, NY.

Analytical Testing Parameters

Client Sample ID: 33
Lab Sample ID: J7D0690-18
Sample Type: Grab

Collected By: RF-Client
Collection Date: 04/05/17
Collection Time: 07:01

Table with 9 columns: Lead and/or Copper, Total - ICP/MS, Result, AL, PQL, Units, Note, Prepared, Analyzed, Lab. Row 1: Lead, 0.00179, 0.0150, 0.000500, mg/L, 04/13/17 1200, 04/13/17 1541, NY.

Analytical Testing Parameters

Client Sample ID: 30
Lab Sample ID: J7D0690-19
Sample Type: Grab

Collected By: RF-Client
Collection Date: 04/05/17
Collection Time: 07:11

Table with 9 columns: Lead and/or Copper, Total - ICP/MS, Result, AL, PQL, Units, Note, Prepared, Analyzed, Lab. Row 1: Lead, 0.00370, 0.0150, 0.000500, mg/L, 04/12/17 0854, 04/13/17 1541, NY.

Analytical Testing Parameters

Client Sample ID: 8
Lab Sample ID: J7D0690-20
Sample Type: Grab

Collected By: RF-Client
Collection Date: 04/05/17
Collection Time: 06:41

Table with 9 columns: Lead and/or Copper, Total - ICP/MS, Result, AL, PQL, Units, Note, Prepared, Analyzed, Lab. Row 1: Lead, 0.00263, 0.0150, 0.000500, mg/L, 04/13/17 1200, 04/13/17 1541, NY.



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J7D0690

Analytical Testing Parameters

Client Sample ID: 5
Lab Sample ID: J7D0690-21
Sample Type: Grab

Collected By: RF-Client
Collection Date: 04/05/17
Collection Time: 06:37

Table with 9 columns: Lead and/or Copper, Total - ICP/MS, Result, AL, PQL, Units, Note, Prepared, Analyzed, Lab. Row 1: Lead, 0.00897, 0.0150, 0.000500, mg/L, 04/13/17 1200, 04/13/17 1541, NY.

Analytical Testing Parameters

Client Sample ID: 27
Lab Sample ID: J7D0690-22
Sample Type: Grab

Collected By: RF-Client
Collection Date: 04/05/17
Collection Time: 07:06

Table with 9 columns: Lead and/or Copper, Total - ICP/MS, Result, AL, PQL, Units, Note, Prepared, Analyzed, Lab. Row 1: Lead, 0.00776, 0.0150, 0.000500, mg/L, 04/12/17 0854, 04/13/17 1541, NY.

Analytical Testing Parameters

Client Sample ID: 28
Lab Sample ID: J7D0690-23
Sample Type: Grab

Collected By: RF-Client
Collection Date: 04/05/17
Collection Time: 07:06

Table with 9 columns: Lead and/or Copper, Total - ICP/MS, Result, AL, PQL, Units, Note, Prepared, Analyzed, Lab. Row 1: Lead, 0.00398, 0.0150, 0.000500, mg/L, 04/12/17 0854, 04/13/17 1541, NY.

Analytical Testing Parameters

Client Sample ID: 6
Lab Sample ID: J7D0690-24
Sample Type: Grab

Collected By: RF-Client
Collection Date: 04/05/17
Collection Time: 06:35

Table with 9 columns: Lead and/or Copper, Total - ICP/MS, Result, AL, PQL, Units, Note, Prepared, Analyzed, Lab. Row 1: Lead, 0.0271, 0.0150, 0.000500, mg/L, G, 04/12/17 0854, 04/13/17 1541, NY.



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J7D0690

Analytical Testing Parameters

Client Sample ID: 38
Lab Sample ID: J7D0690-25
Sample Type: Grab

Collected By: RF-Client
Collection Date: 04/05/17
Collection Time: 07:03

Table with 9 columns: Lead and/or Copper, Total - ICP/MS, Result, AL, PQL, Units, Note, Prepared, Analyzed, Lab. Row 1: Lead, 0.0245, 0.0150, 0.000500, mg/L, G, 04/13/17 1200, 04/13/17 1541, NY.

Analytical Testing Parameters

Client Sample ID: 46
Lab Sample ID: J7D0690-26
Sample Type: Grab

Collected By: RF-Client
Collection Date: 04/05/17
Collection Time: 07:02

Table with 9 columns: Lead and/or Copper, Total - ICP/MS, Result, AL, PQL, Units, Note, Prepared, Analyzed, Lab. Row 1: Lead, 0.00903, 0.0150, 0.000500, mg/L, 04/13/17 1200, 04/13/17 1541, NY.

Analytical Testing Parameters

Client Sample ID: 9
Lab Sample ID: J7D0690-27
Sample Type: Grab

Collected By: RF-Client
Collection Date: 04/05/17
Collection Time: 06:32

Table with 9 columns: Lead and/or Copper, Total - ICP/MS, Result, AL, PQL, Units, Note, Prepared, Analyzed, Lab. Row 1: Lead, 0.00408, 0.0150, 0.000500, mg/L, 04/12/17 0854, 04/13/17 1541, NY.

Analytical Testing Parameters

Client Sample ID: 35
Lab Sample ID: J7D0690-28
Sample Type: Grab

Collected By: RF-Client
Collection Date: 04/05/17
Collection Time: 07:02

Table with 9 columns: Lead and/or Copper, Total - ICP/MS, Result, AL, PQL, Units, Note, Prepared, Analyzed, Lab. Row 1: Lead, 0.00902, 0.0150, 0.000500, mg/L, 04/13/17 1200, 04/13/17 1541, NY.



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J7D0690

Analytical Testing Parameters

Client Sample ID: 4
Lab Sample ID: J7D0690-29
Sample Type: Grab

Collected By: RF-Client
Collection Date: 04/05/17
Collection Time: 06:40

Table with 9 columns: Lead and/or Copper, Total - ICP/MS, Result, AL, PQL, Units, Note, Prepared, Analyzed, Lab. Row 1: Lead, 0.0217, 0.0150, 0.000500, mg/L, G, 04/12/17 0854, 04/13/17 1541, NY.

Analytical Testing Parameters

Client Sample ID: 37
Lab Sample ID: J7D0690-30
Sample Type: Grab

Collected By: RF-Client
Collection Date: 04/05/17
Collection Time: 09:03

Table with 9 columns: Lead and/or Copper, Total - ICP/MS, Result, AL, PQL, Units, Note, Prepared, Analyzed, Lab. Row 1: Lead, 0.0131, 0.0150, 0.000500, mg/L, 04/13/17 1200, 04/13/17 1541, NY.

Analytical Testing Parameters

Client Sample ID: 42
Lab Sample ID: J7D0690-31
Sample Type: Grab

Collected By: RF-Client
Collection Date: 04/05/17
Collection Time: 07:05

Table with 9 columns: Lead and/or Copper, Total - ICP/MS, Result, AL, PQL, Units, Note, Prepared, Analyzed, Lab. Row 1: Lead, 0.0148, 0.0150, 0.000500, mg/L, 04/13/17 1200, 04/13/17 1541, NY.

Analytical Testing Parameters

Client Sample ID: 31
Lab Sample ID: J7D0690-32
Sample Type: Grab

Collected By: RF-Client
Collection Date: 04/05/17
Collection Time: 07:00

Table with 9 columns: Lead and/or Copper, Total - ICP/MS, Result, AL, PQL, Units, Note, Prepared, Analyzed, Lab. Row 1: Lead, 0.00541, 0.0150, 0.000500, mg/L, 04/13/17 1200, 04/13/17 1541, NY.





Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J7D0690

Analytical Testing Parameters

Client Sample ID: 13
Lab Sample ID: J7D0690-33
Sample Type: Grab

Collected By: RF-Client
Collection Date: 04/05/17
Collection Time: 07:29

Table with 9 columns: Lead and/or Copper, Total - ICP/MS, Result, AL, PQL, Units, Note, Prepared, Analyzed, Lab. Row 1: Lead, 0.00173, 0.0150, 0.000500, mg/L, 04/12/17 0854, 04/13/17 1541, NY

Analytical Testing Parameters

Client Sample ID: 18
Lab Sample ID: J7D0690-34
Sample Type: Grab

Collected By: RF-Client
Collection Date: 04/05/17
Collection Time: 07:20

Table with 9 columns: Lead and/or Copper, Total - ICP/MS, Result, AL, PQL, Units, Note, Prepared, Analyzed, Lab. Row 1: Lead, 0.00239, 0.0150, 0.000500, mg/L, 04/12/17 0854, 04/13/17 1541, NY

Analytical Testing Parameters

Client Sample ID: 21
Lab Sample ID: J7D0690-35
Sample Type: Grab

Collected By: RF-Client
Collection Date: 04/05/17
Collection Time: 07:21

Table with 9 columns: Lead and/or Copper, Total - ICP/MS, Result, AL, PQL, Units, Note, Prepared, Analyzed, Lab. Row 1: Lead, 0.00193, 0.0150, 0.000500, mg/L, 04/12/17 0854, 04/13/17 1541, NY

Analytical Testing Parameters

Client Sample ID: 14
Lab Sample ID: J7D0690-36
Sample Type: Grab

Collected By: RF-Client
Collection Date: 04/05/17
Collection Time: 07:29

Table with 9 columns: Lead and/or Copper, Total - ICP/MS, Result, AL, PQL, Units, Note, Prepared, Analyzed, Lab. Row 1: Lead, 0.00222, 0.0150, 0.000500, mg/L, 04/13/17 1200, 04/13/17 1541, NY



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J7D0690

Analytical Testing Parameters

Client Sample ID: 15
Lab Sample ID: J7D0690-37
Sample Type: Grab

Collected By: RF-Client
Collection Date: 04/05/17
Collection Time: 07:31

Table with 9 columns: Lead and/or Copper, Total - ICP/MS, Result, AL, PQL, Units, Note, Prepared, Analyzed, Lab. Row 1: Lead, 0.000719, 0.0150, 0.000500, mg/L, 04/13/17 1200, 04/13/17 1541, NY

Analytical Testing Parameters

Client Sample ID: 17
Lab Sample ID: J7D0690-38
Sample Type: Grab

Collected By: RF-Client
Collection Date: 04/05/17
Collection Time: 07:26

Table with 9 columns: Lead and/or Copper, Total - ICP/MS, Result, AL, PQL, Units, Note, Prepared, Analyzed, Lab. Row 1: Lead, 0.00236, 0.0150, 0.000500, mg/L, 04/12/17 0854, 04/13/17 1541, NY

Analytical Testing Parameters

Client Sample ID: 12
Lab Sample ID: J7D0690-39
Sample Type: Grab

Collected By: RF-Client
Collection Date: 04/05/17
Collection Time: 07:28

Table with 9 columns: Lead and/or Copper, Total - ICP/MS, Result, AL, PQL, Units, Note, Prepared, Analyzed, Lab. Row 1: Lead, 0.00269, 0.0150, 0.000500, mg/L, 04/12/17 0854, 04/13/17 1541, NY

Laboratory

NY: Microbac Laboratories, Inc., New York Division

Definitions

- AL: Action Level
AL: US EPA Action Level
RL: Reporting Limit
G: Result fails applicable NYS drinking water standards

Cooler Receipt Log

Cooler ID: Default Cooler Temp: °C



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J7D0690

Cooler Inspection Checklist

|  |     |  |     |
|--|-----|--|-----|
| Custody Seals Intact and/or No Evidence of Tampering | Yes | Containers Intact                      | Yes |
| COC/Labels Agree                                     | Yes | Preservation Correct (or not required) | Yes |
| Received on Ice (or not required)                    | Yes |  |     |

Project Requested Certification(s)

Microbac Laboratories, Inc., New York Division  
NY Lab ID No.: 10795

New York State Department of Health

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

Reviewed and Approved By:

Andrew Canale  
Project Manager  
04/18/2017 12:48

**Go Green:** Contact Andrew Canale to set up email reporting and invoicing options .

*The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. For any feedback concerning our services, please contact Andrew Canale, Project Manager at [andrew.canale@microbac.com](mailto:andrew.canale@microbac.com). You may also contact Michael Fifield, Managing Director at [michael.fifield@microbac.com](mailto:michael.fifield@microbac.com) or Robert Crookston, President at [robert.crookston@microbac.com](mailto:robert.crookston@microbac.com).*

**Microbac Laboratories, Inc.** Samples must be returned on ice  
**CHAIN OF CUSTODY**

CB-3

MNY Workorder #

| Client Information   |  | Billing/Invoice     |              | Analyst Requested                           |   | Receiving Info (Lab Use Only) |          |
|----------------------|--|---------------------|--------------|---|---|-------------------------------|----------|
| Name:                | Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCES | Quote ID:           |              | Ice:  | YES NO                                      | Container Material:           | YES NO   |
| Address:             | 20104 NYS Route 3<br>Watertown, NY 13601       | Project:            | Lead Testing | Cooler:                                     | YES NO                                      | Container Size (in MI):       | YES NO   |
| Contact:             | Ray Filley                                     | PO#:                |              | Sample Temp:                                | YES NO                                      | Preservative:                 | YES NO   |
| Phone:               | 315-779-7054                                   | Rush TAT Est. Days: | 2-5 5-7 7-10 | Cooler Seal:                                | YES NO                                      | Accepted?                     | YES NO   |
| Project:             | Lead Testing                                   | Release to DOH: Yes |              | Pickup:                                     | YES NO                                      | Dropoff:                      | C W      |
| Quote ID:            |  | Email Results: Yes  |              | Dropoff:                                    | C W   | Accepted?                     | YES NO   |
| Rush TAT Est. Days:  | 2-5 5-7 7-10                                   | Fax Results: Yes    |              | Dropoff:                                    | C W   | Accepted?                     | YES NO   |
| Release to DOH: Yes  |  |                     |              | Dropoff:                                    | C W   | Accepted?                     | YES NO   |
| Email Results: Yes   |  |                     |              | Dropoff:                                    | C W   | Accepted?                     | YES NO   |
| Fax Results: Yes     |  |                     |              | Dropoff:                                    | C W   | Accepted?                     | YES NO   |
| Sample Information   |  | Matrix Type         |              | Number of Containers for Analysis Requested |   | Comments/Field Data           |          |
| Description/Location | Date   | Time                | Initial      | Matrix Type                                 | Number of Containers for Analysis Requested | Comments                      | Comments |
| 2                    | 4/5/17   | 6:50                | RF           | 250 HNO3                                    |   |                               |          |
| 10                   |  | 6:41                |              |   |   |                               |          |
| 48                   |  | 7:05                |              |   |   |                               |          |
| 40                   |  | 7:04                |              |   |   |                               |          |
| 39                   |  | 7:04                |              |   |   |                               |          |
| 36                   |  | 7:02                |              |   |   |                               |          |
| 7                    |  | 6:43                |              |   |   |                               |          |
| 1                    |  | 6:33                |              |   |   |                               |          |
| Sampled:             | Ray Filley                                     | Signature:          |              | Date/Time:                                  | 4/5/17                                      |                               |          |
| Received:            | Dennis Beechek                                 | Signature:          |              | Date/Time:                                  | 4-6-17 09:22                                |                               |          |
| Received:            | Dennis Beechek                                 | Signature:          |              | Date/Time:                                  | 4-6-17 13:05                                |                               |          |
| Received:            | Danielle Gower                                 | Signature:          |              | Date/Time:                                  | 4/6/17 13:05                                |                               |          |
| Received:            |  | Signature:          |              | Date/Time:                                  |   |                               |          |
| Received:            |  | Signature:          |              | Date/Time:                                  |   |                               |          |



J7D0690

NO ACID

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory.  
 By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with the terms and conditions of the subcontract.

**GB-3**

**Microbac Laboratories, Inc. Samples must be returned on ice**  
**CHAIN OF CUSTODY**

MNY Workorder #

| Client Information  |   | Billing/Invoice |  |
|---------------------|---|-----------------|--|
| Name:               | Jefferson-Lewis-Hamilton-Heckler Oneida BOCES |                 |  |
| Address:            | 20104 NYS Route 3<br>Watertown, NY 13601      |                 |  |
| Contact:            | Ray Filley                                    |                 |  |
| Phone:              | 315-779-7054                                  |                 |  |
| Project:            | Lead Testing                                  |                 |  |
| Quote ID:           |   | PO#:            |  |
| Rush TAT Bur. Days: | 2-5 5-7 7-10                                  | Date Req.:      |  |
| Release to DOH: Yes |   |                 |  |
| Email Results: Yes  |   |                 |  |
| Fax Results: Yes    |   |                 |  |
|                     | rfilley@boces.com / fhauck@boes.com           |                 |  |

  

| Sample Information   |        |      |         | Analysis Requested |   |
|----------------------|--------|------|---------|--------------------|---|
| Description/Location | Date   | Time | Initial | Matrix Type        | Number of Containers for Analysis Requested |
| 1 34                 | 4/5/17 | 7:01 | RF      |                    |   |
| 2 24                 |        | 7:05 |         |                    |   |
| 3 25                 |        | 7:09 |         |                    |   |
| 4 29                 |        | 7:10 |         |                    |   |
| 5 47                 |        | 7:25 |         |                    |   |
| 6 19                 |        | 7:22 |         |                    |   |
| 7 16                 |        | 7:21 |         |                    |   |
| 8 11                 |        | 7:22 |         |                    |   |

  

| Sampled:  | Print Name and Company | Signature   | Date/Time    | Comments |
|-----------|------------------------|-------------|--------------|----------|
| Received: | Ray Filley             | [Signature] | 4/5/17       |          |
| Received: | Deron Biecholski MLI   | [Signature] | 4-6-17 09:02 |          |
| Received: | Danella Biecholski MLI | [Signature] | 4-6-17 13:05 |          |
| Received: | Danella Biecholski MLI | [Signature] | 4/6/17 13:05 |          |
| Received: |                        |             |              |          |

  

| Receiving Info (Lab Use Only) |        |
|-------------------------------|--------|
| Ice:                          | YES NO |
| Cooler:                       | YES NO |
| Sample Temp:                  |        |
| Cooler Seal:                  | YES NO |
| Pickup:                       | YES NO |
| Dropoff:                      | C W    |
| Accepted?                     | YES NO |
| Container Material:           |        |
| Container Size (in Mil)       |        |
| Preservative:                 |        |
| Comments/Field Data           |        |



J7D0690

NO ACID

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory.  
 By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement.

**CB-3**

**Microbac Laboratories, Inc. Samples must be returned on ice**  
**CHAIN OF CUSTODY**

MNY Workorder #

| <b>Client Information</b>                           |                                  | <b>Billing/Invoicing</b>                    |         |
|---|----------------------------------|---|---------|
| Name: Jefferson-Lewis-Hamilton-Herkimer-Onida BOCCS | 20104 NYS Route 3                |   |         |
| Address: Watertown, NY 13601                        | Ray Filley                       |   |         |
| Contact: 315-779-7054                               | Lead Testing                     |   |         |
| Project: Lead Testing                               | PO#:                             | Date Req:                                   |         |
| Quote ID:   | Ruth TAT Bar, Days: 2-5 5-7 7-10 | Date Req:                                   |         |
| Release to DOH: Yes                                 | Email Results: Yes               | Fax Results: Yes                            |         |
| rfilley@boces.com / fhauck@boces.com                |                                  | 200.8 Lead                                  |         |
| <b>Sample Information</b>                           |                                  | <b>Analysis Requested</b>                   |         |
| Description/Location                                | Date                             | Time  | Initial |
| 3   | 4/5/17                           | 639   | RF      |
| 33  |                                  | 701   |         |
| 30  |                                  | 711   |         |
| 8   |                                  | 641   |         |
| 5   |                                  | 637   |         |
| 27  |                                  | 706   |         |
| 28  |                                  | 706   |         |
| 6   |                                  | 635   |         |
| Matrix Type   |                                  | Number of Containers for Analysis Requested |         |
| HNO3  |                                  | P   |         |
| 250   |                                  |   |         |
| Comments/Field Data                                 |                                  | Comments                                    |         |
|   |                                  | NO AERO                                     |         |



J7D0690

Print Name and Company  
 Sampled: Ray Filley  
 Received: Debra Beekle MIT  
 Received: [Signature] MIT  
 Received: DANIELA GORV  
 Received: [Signature]  
 Received: [Signature]  
 Signature: [Signatures]  
 Date/Time: 4/5/17 0848  
 4-6-17 0932  
 4-6-17 1305  
 4/10/17 1205

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory.  
 By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement.

# Microbac Laboratories, Inc. Samples must be returned on ice

## CHAIN OF CUSTODY

*G-3*

MNY Workorder #

| <b>Client Information</b>   |   | <b>Billing/Invoice:</b>                     |             |
|---|---|---|-------------|
| Name:   | Jefferson-Lewis-Hamilton-Herkimer-Oneida-BOCES                      |   |             |
| Address:  | 20104 NYS Route 3<br>Watertown, NY 13601                            |   |             |
| Contact:  | Ray Filley  |   |             |
| Phone:  | 315-779-7054  |   |             |
| Project:  | Lead Testing  |   |             |
| Quote ID:   |   | PO#:  |             |
| Rush TAT Bus. Days:   | 2-5 5-7 7-10  | Date Req.:                                  |             |
| Release to DOH: Yes   |   |   |             |
| Email Results: Yes  |   |   |             |
| Fax Results: Yes  |   |   |             |
|   | <u>rfilley@boces.com</u>  |   |             |
|   | <u>fhauck@boces.com</u>   |   |             |
| <b>Sample Information</b>   |   |   |             |
| Description/Location  | Date  | Time  | Initial     |
| 1 38  | 4/5/17  | 703   | RF          |
| 2 46  |   | 7:02  |             |
| 3 9   |   | 6:32  |             |
| 4 35  |   | 7:02  |             |
| 5 4   |   | 6:40  |             |
| 6 37  |   | 9:03  |             |
| 7 42  |   | 7:05  |             |
| 8 31  |   | 7:00  |             |
| <b>Receiving Info (Lab Use Only)</b>  |   |   |             |
| Ice:  | YES <input type="checkbox"/> NO <input checked="" type="checkbox"/> |   |             |
| Cooler:   | YES <input type="checkbox"/> NO <input checked="" type="checkbox"/> |   |             |
| Sample Temp:  |   |   |             |
| Cooler Seal:  | YES <input type="checkbox"/> NO <input type="checkbox"/>            |   |             |
| Pickup:   | YES <input type="checkbox"/> NO <input type="checkbox"/>            |   |             |
| Dropoff:  | C W   |   |             |
| Accepted?   | YES <input type="checkbox"/> NO <input type="checkbox"/>            |   |             |
| Container Material  |   |   |             |
| Container Size (in ML)  |   |   |             |
| Preservative  |   |   |             |
| Comments/Field Data   |   |   |             |
| Analysis Requested  |   | Number of Containers for Analysis Requested |             |
| 200.8 Lead  |   | P   |             |
| 250   |   | HNO3  |             |
| <b>Signature</b>  |   |   |             |
| Sampled:  | <i>Ray Filley</i>   | Date/Time                                   | 4/5/17 0930 |
| Received:   | <i>Debra Biedek</i>   |   | 9:17 0922   |
| Received:   | <i>Debra Biedek</i>   |   | 4:17 1309   |
| Received:   | <i>Danell Gaur</i>  |   | 4/17 1305   |
| Received:   |   |   |             |
| Received:   |   |   |             |
| <b>Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory.</b> |   |   |             |



J7D0690

**CB-3**

**Microbac Laboratories, Inc. Samples must be returned on ice**  
**CHAIN OF CUSTODY**

MNY Workorder #

| Client Information   |   | Billing/Invoice                      |         | Analysis Requested                          |                     |
|--|---|--------------------------------------|---------|---|---------------------|
| Name:  | Jefferson-Lewis-Hamilton-Heikimr Oneida BOCES |                                      |         |   |                     |
| Address:   | 20104 NYS Route 3                             |                                      |         |   |                     |
| Contact:   | Watertown, NY 13601                           |                                      |         |   |                     |
| Phone:   | Ray Filley                                    |                                      |         |   |                     |
| Project:   | 315-779-7054                                  |                                      |         |   |                     |
| Quote ID:  | Lead Testing                                  |                                      |         |   |                     |
| Rush TAT Bur. Days:  | 2-5   | 5-7                                  | 7-10    | PO#:  |                     |
| Release to DOH:  | Yes   |                                      |         | Date Req.:                                  |                     |
| Email Results:   | Yes   |                                      |         |   |                     |
| Fax Results:   | Yes   |                                      |         |   |                     |
|  |   | rifilley@boces.com / fhack@boces.com |         | 200.8 Lead                                  |                     |
|  |   |                                      |         | P   |                     |
|  |   |                                      |         | 250   |                     |
|  |   |                                      |         | HNO3  |                     |
| Sample Information   |   | Matrix                               |         | Number of Containers for Analysis Requested |                     |
| Description/Location   | Date  | Time                                 | Initial | Type  | Comments/Field Data |
| 1  | 13  | 4/5/17                               | 729 RF  |   |                     |
| 2  | 18  |                                      | 720     |   |                     |
| 3  | 21  |                                      | 721     |   |                     |
| 4  | 14  |                                      | 729     |   |                     |
| 5  | 15  |                                      | 731     |   |                     |
| 6  | 17  |                                      | 726     |   |                     |
| 7  | 12  |                                      | 728     |   |                     |
| 8  |   |                                      |         |   |                     |
| Sampled:   |   | Ray Filley                           |         | Signature                                   | Date/Time           |
| Received:  |   | Deron Bleeche                        |         |   | 4/5/17              |
| Received:  |   | Deron Bleeche                        |         |   | 4-6-17 9:22         |
| Received:  |   | Dannell Gower                        |         |   | 4-6-17 1305         |
| Received:  |   |                                      |         |   | 4/10/17 1305        |
| Received:  |   |                                      |         |   |                     |
| Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. |   |                                      |         |   |                     |



J7D0690

*No lead*